



**NOTES:**

- CHCTRL1: CHILLER CONTROL
- CHLK1: CHILLER LOCKOUT
- DFE: DEFROST FLUID EXCHANGER VALVE
- MWFS: MASTER WARM FLUID SOLENOID VALVE
- TSV: TEMPERING SOLENOID VALVE
- WFS: WARM FLUID SUPPLY TEMPERATURE
- POP: PUMP OUTLET PRESSURE
- PIP: PUMP INLET PRESSURE
- PDPS: PUMP DIFFERENTIAL PRESSURE SWITCH
- SCFZ1: SECONDARY COOLANT FREEZE STAT. 1
- SCFZ2: SECONDARY COOLANT FREEZE STAT. 2
- SCFS: SECONDARY COOLANT FLOW SWITCH
- SCST: SECONDARY COOLANT SUPPLY TEMPERATURE
- SCSP: SECONDARY COOLANT SUPPLY PRESSURE
- SCRT: SECONDARY COOLANT RETURN TEMPERATURE
- SCRCP: SECONDARY COOLANT RETURN PRESSURE
- PCS1: PUMP CONTROL SENSING 1
- PCS2: PUMP CONTROL SENSING 2
- PCS3: PUMP CONTROL SENSING 3

--	----	07
--	----	06
--	----	05
--	----	04
--	----	03
--	----	02
2014-11-04	Update Logo & Adress	01
DATE	DESCRIPTION	REV.

SYSTEM :  
**REFRIGERATION**

AUTOMATISATION / CONTROL :



**Parker**  
Micro Thermo Technologies™  
12855 Rue Brault, Mirabel  
Quebec, Canada, J7J 0C4  
Tel: (450) 668-3033  
Fax: (450) 668-2695

TITLE:  
**SECONDARY COOLING SYSTEM (PROPOSED)  
1 CHILLER**

PART# :  
**XXX-XXX**

Drawn By :	Designed By :	Approved By :	Revision :
G.Q.	L.M.	A.H.	01
Scale :	Date :	File Name :	
N.T.S	2004-08-23	A-002 SEC-COOL-1CHILLER	