



- NOTES:**
- CHCTRL1: CHILLER CONTROL
  - CHLK1: CHILLER LOCKOUT
  - DFE: DEFROST FLUID EXCHANGER VALVE
  - MWFS: MASTER WARM FLUID SOLENOID VALVE
  - TSV: TEMPERING SOLENOID VALVE
  - WFS: WARM FLUID SUPPLY TEMPERATURE
  - POP: PUMP OUTLET PRESSURE
  - PIP: PUMP INLET PRESSURE
  - PDPS: PUMP DIFFERENTIAL PRESSURE SWITCH
  - SCFZ1: SECONDARY COOLANT FREEZE STAT. 1
  - SCFZ2: SECONDARY COOLANT FREEZE STAT. 2
  - SCFS: SECONDARY COOLANT FLOW SWITCH
  - SCST: SECONDARY COOLANT SUPPLY TEMPERATURE
  - SCSP: SECONDARY COOLANT SUPPLY PRESSURE
  - SCRT: SECONDARY COOLANT RETURN TEMPERATURE
  - SCRCP: SECONDARY COOLANT RETURN PRESSURE
  - PCS1: PUMP CONTROL SENSING 1
  - PCS2: PUMP CONTROL SENSING 2
  - PCS3: PUMP CONTROL SENSING 3

--	----	07
--	----	06
--	----	05
--	----	04
--	----	03
--	----	02
2014-11-03	Update Logo & Adress	01
DATE	DESCRIPTION	REV.

SYSTEM :  
**REFRIGERATION**

AUTOMATISATION / CONTROL :



**Micro Thermo Technologies™**  
12855 Rue Brault, Mirabel  
Quebec, Canada, J7J 0C4  
Tel: (450) 668-3033  
Fax: (450) 668-2695

TITLE:  
**SECONDARY COOLING SYSTEM (PROPOSED)  
2 CHILLERS**

PART# :  
**XXX-XXX**

Drawn By : G.Q.	Designed By : L.M.	Approved By : A.H.	Revision : 01
Scale : N.T.S	Date : 2004-08-23	File Name : A-103 SEC-COOL-2CHILLERS	