



Dimension 4" X 12.5"

- EACH CIRCUIT CONTROLLER CONTROLS A MAXIMUM OF FIVE REFRIGERATION CIRCUITS.
- 24Vac CENTER TAP TRANSFORMER REQUIRED (12VA PER CONTROLLER).
- RELAY OUTPUT RATING 2 Amps.
- SEE DRAWING C-005 FOR POWER REQUIREMENT.

**LEGEND**

- NET NET ECHOLON TYPE #18, STRANDED, 7/26 UTP (UNSHIELDED TWISTED PAIR) BELDEN 8461 TYPE OR EQUIVALENT .
- PRE-WIRED CONNECTIONS
- FIELD INSTALLED WIRING
- FIELD INSTALLED BY ELECTRICIAN

DATE	DESCRIPTION	REV.
--	----	07
--	----	06
--	----	05
--	----	04
--	----	03
--	----	02
2012-05-16	Modification on DATA Description	01

SYSTEM :  
**REFRIGERATION**

AUTOMATISATION / CONTROL :



**Micro Thermo Technologies™**  
12855 Rue Brault, Mirabel  
Quebec, Canada, J7J 0C4  
Tel: (450) 668-3033  
Fax: (450) 668-2695

TITLE:  
**CIRCUIT CONTROLLER  
CONNECTION DIAGRAM  
24 VOLT POWER**

PART# :  
**9XX-634B**

Drawn By :	Designed By :	Approved By :	Revision :
G.Q.	L.M.	A.H.	02
Scale :	Date :	File Name :	
N.T.S	2004-08-23	A-302 MT-CKT-CON-24V	