

OPTION #1

NETWORK CONNECT

CONNECT BY SNVT BINDING FROM STORE TEMPERATURE/HUMIDITY SENSOR (ANALOG).


MICRO THERMO
P/N 23-0043

OPTION #2



PHYSICAL CONNECT

RELATIVE HUMIDITY SENSOR TO BE INSTALLED CLOSE TO REFRIGERATED CASES OR DOORS,

USE MICRO THERMO SENSOR
P/N #23-0026 ONLY.
10K TYPE 2 + HUMIDITY REL.



PANEL 24"X24"X10"



DATE	DESCRIPTION	REV.
--	----	07
--	----	06
--	----	05
--	----	04
--	----	03
2015-10-22	Révisé le numéro de pièce 3744 pour 374B	02
2007-02-12	Modifier grandeur panneau	01

SYSTEM :
ANTI-SWEAT

AUTOMATISATION / CONTROL :



Micro Thermo Technologies™
12855 Rue Brault, Mirabel
Quebec, Canada J7J 0C4
Tel: (450) 668-3033
Fax: (450)668-2695

TITLE:
ANTI-SWEAT 24 RELAYS 30A
24" X 24" X 10"

PART#:
961-0106

Drawn By : D.P.	Designed By : L.M.	Approved By : A.H.	Revision : 02
Scale : N.T.S	Date : 2007-02-12	File Name : Anti-sweat 24 relays 30A	