



Dimension 4" X 12.5"

- EACH CIRCUIT CONTROLLER CONTROLS A MAXIMUM OF FIVE REFRIGERATION CIRCUITS.
- 24Vac CENTER TAP TRANSFORMER REQUIRED (12VA PER CONTROLLER).
- RELAY OUTPUT RATING 2 Amps.
- SEE DRAWING C-005 FOR POWER REQUIREMENT.

LEGEND

- NET NET NET ECHELON TYPE 2#18, STRANDED, 7/26 UTP (UNSHIELDED TWISTED PAIR) BELDEN 8461 TYPE OR EQUIVALENT.
- PRE-WIRED CONNECTIONS
- FIELD INSTALLED WIRING
- FIELD INSTALLED BY ELECTRICIAN

DATE	DESCRIPTION	REV.
2014-11-12	Update Logo & Adress	02
2012-05-16	Modification on DATA Description	01
--	----	07
--	----	06
--	----	05
--	----	04
--	----	03

SYSTEM :
REFRIGERATION

AUTOMATISATION / CONTROL :



Micro Thermo Technologies™

12855 Rue Brault, Mirabel
Quebec, Canada, J7J 0C4
Tel: (450) 668-3033
Fax: (450) 668-2695

TITLE:
**CIRCUIT CONTROLLER
CONNECTION DIAGRAM
120 VOLT POWER**

PART# :
9XX-634B

Drawn By : G.Q.	Designed By : L.M.	Approved By : A.H.	Revision : 02
Scale : N.T.S	Date : 2004-08-23	File Name : A-309 MT-CKT-CON-120V	